

Annual Drinking Water Quality Report

Springdale Town Water System 2024

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality of the water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water sources have been determined to be from groundwater and surface water sources. Our water sources are Big Spring, Virgin River Intake, and Hummingbird Well. We also purchase water from Zion Canyon Water system (UTAH27051).

The Drinking Water Source Protection Plan for ***Springdale Town Water System*** is available for your review. It contains information about source protection zones, potential contamination sources and management strategies to protect our drinking water. Our sources have been determined to have a low level of susceptibility from potential contamination.

There are many connections to our water distribution system. When connections are properly installed and maintained, the concerns are very minimal. However, unapproved and improper piping changes or connections can adversely affect not only the availability, but also the quality of the water. A cross connection may let polluted water or even chemicals mingle into the water supply system when not properly protected. This not only compromises the water quality but can also affect your health. So, what can you do? Do not make or allow improper connections at your homes. Even that unprotected garden hose lying in the puddle next to the driveway is a cross connection. The unprotected lawn sprinkler system after you have fertilized or sprayed is also a cross connection. When the cross connection is allowed to exist at your home, it will affect you and your family first. If you would like to learn more about helping to protect the quality of our water, call us for further information about ways you can help.

This report shows our water quality and what it means to you as our customer.

If you have any questions or concerning your water utility, please contact Rob Totten at (435)-772-3434. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled Town Council meetings. The meetings are held on **the second Wednesday of every month at 5:00 pm at the community center.**

Springdale Town Water System routinely monitors for constituents in our drinking water in accordance with the Federal and Utah State laws. The following table shows the results of our monitoring for the period of January 1st to December 31st, 2024. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It is important to remember that the presence of these constituents does not necessarily pose a health risk.

In the following table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

ND/Low - High - For water systems that have multiple sources of water, the Utah Division of Drinking Water has given water systems the option of listing the test results of the constituents in one table, instead of multiple tables. To accomplish this, the lowest and highest values detected in the multiple sources are recorded in the same space in the report table.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (ug/l) - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or Nanograms per liter (nanograms/l) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Date- Because of required sampling time frames i.e. yearly, 3 years, 4 years and 6 years, sampling dates may seem outdated.

Waivers (W)- Because some chemicals are not used or stored in areas around drinking water sources, some water systems have been given waivers that exempt them from having to take certain chemical samples, these waivers are also tied to Drinking Water Source Protection Plans.

TEST RESULTS							
Contaminant	Violation Y/N	Level Detected ND/Low-High	Unit Measurement	MCLG	MCL	Date Sampled	Likely Source of Contamination
Microbiological Contaminants							
Total Coliform Bacteria	N	ND	N/A	0	Presence of coliform bacteria in 5% of monthly samples	2024	Naturally present in the environment
Fecal coliform and <i>E.coli</i>	N	N/A	N/A	0	If a routine sample and repeat sample are total coliform positive, and one is also fecal coliform or <i>E. coli</i> positive	2024	Human and animal fecal waste

Turbidity for Surface Water	N	0.18	NTU	N/A	0.5 in at least 95% of the samples and must never exceed 5.0	2024	Soil Runoff (highest single measurement & the lowest monthly percentage of samples meeting the turbidity limit)
-----------------------------	---	------	-----	-----	--	------	--

Inorganic Contaminants

Arsenic	N	.9	ppb	0	10	2024	Erosion of natural deposit runoff from orchards; runoff from glass and electronics production wastes
Barium	N	0.078	ppm	2	2	2024	Discharge of drilling waste discharge from metal refineries; erosion of natural deposits
Carbon, Total Organic (TOC)	N	0-2.11	ppm	NA	TT	2024	Naturally present in the environment
Copper a. 90% results b. # of sites that exceed the AL	N	a.0.019 b.0	ppm	1.3	AL=1.3	2023	Corrosion of household plumbing systems; erosion of natural deposits
Fluoride	N	ND	ppm	4	4	2024	Erosion of natural deposit water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead a. 90% results b. # of sites that exceed the AL	N	a. 1 b.0	ppb	0	AL=15	2023	Corrosion of household plumbing systems, erosion of natural deposits
Nitrate (as Nitrogen)	N	ND	ppm	10	10	2024	Runoff from fertilizer use leaching from septic tanks sewage; erosion of natural deposits
Selenium	N	ND	ppb	50	50	2024	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium	N	73.739	ppm	None set by EPA	None set by EPA	2024	Erosion of natural deposit discharge from refineries factories; runoff from landfills.
Sulfate	N	100.151	ppm	1000	1000	2024	Erosion of natural deposit discharge from refineries factories; runoff from landfills, runoff from cropland
TDS (Total Dissolved solids)	N	460	ppm	2000	2000	2024	Erosion of natural deposit

Disinfection By-products

TTHM [Total trihalomethanes]	N	13.39-56.24	ppb	0	80	2024	By-product of drinking water disinfection
Haloacetic Acids	N	3.51-29.29	ppb	0	60	2024	By-product of drinking water disinfection
Chlorine	N	0.65-0.666	ppb	4000	4000	2020	Water additive used to control microbes

Radioactive Contaminants

Alpha emitters	N	ND-1.6	pCi/l	0	15	2019	Erosion of natural deposit
Radium 226	N	0.18-0.37	pCi/l	0	5	2020	Erosion of natural deposit

Radium 228	N	0.06-0.47	pCi/l	0	5	2020	Erosion of natural deposit
------------	---	-----------	-------	---	---	------	----------------------------

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Springdale Town Water System is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Lead Service Line Inventory Information.

The Town of Springdale has completed an initial lead service line inventory. This inventory included information on the service line material that connects water mains to buildings/houses. Springdale Town Water System determined that all service lines are non-lead.

All sources of drinking water are subject to potential contamination by constituents that are naturally occurring or manmade. Those constituents can be microbes, organic or inorganic chemicals, or radioactive materials. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

MCLs are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care providers about drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

We at Springdale Town Water System work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Springdale Town Water System
PO Box 187
Springdale, UT 84767

June 12, 2025

Brandi Smith
CCR Compliance
Division of Drinking Water
P.O. Box 144830
Salt Lake City, Utah 84114-4830
ddwreports@utah.gov
brandismith@utah.gov

Dear Ms. Smith:

Subject: Consumer Confidence Report for **Springdale Town Water System (UTAH27017)**

Enclosed is a copy of **Springdale Town Water System's** Consumer Confidence Report. It contains the water quality information for our water system for the calendar year 2024 or the most recent sample data.

We have delivered this report to our customers by:

Posting a notice of availability on our Town Website and sending a copy to those who request one. We will also make copies available at the Water Treatment Plant.

If you have any questions, please contact me at 435-772-3434.

Sincerely,



Rob Totten
Springdale Town Water System

